

RESOLUTION NO. 15-_____

WHEREAS, the City of Huntsville Waterworks Utility Board has approved Purchase Requisition #10178280 for the installation of a new dehumidifier at the Lincoln Dallas Water Plant to replace an older unit in the high service pump room at a total estimated cost of \$27,687.00; and

WHEREAS, the estimated cost of said replacement is in excess of \$25,000.00 and requires the consent and approval of the City Council of the City of Huntsville, Alabama;

NOW, THEREFORE, BE IT RESOLVED by the City Council of the City of Huntsville, Alabama, that the installation of a new dehumidifier at the Lincoln Dallas Water Plant to replace an older unit in the high service pump room at a total estimated cost of \$27,687.00 be, and the same is hereby approved and the written consent and approval of the City Council of the City of Huntsville, Alabama, is hereby granted to the City of Huntsville Waterworks Utility Board for the expenditures of sufficient funds from the proper fund belonging to the City of Huntsville Waterworks Utility Board for the payment of the costs thereof.

ADOPTED this the _____ day of _____, 2015.

President of the City Council of
The City of Huntsville, Alabama

APPROVED this the _____ day of _____, 2015.

Mayor of the City of Huntsville,
Alabama



HUNTSVILLE UTILITIES

Electricity – Natural Gas – Water

(256) 535-1200

www.hsvutil.org

P.O. Box 2048
Huntsville, AL 35804

REQUEST FOR APPROVAL

Purchase Requisition #10178280

Purchase Requisition #10178280 – Dehumidifier

Request the installation of a new dehumidifier at the Lincoln Dallas Water Plant to replace an older unit in the high service pump room. Without the dehumidifier, water pipes sweat 15 to 20 gallons of water per day during warm weather. This is an Expense budgeted item, Cost Center #513030, Cost Element #501131.

Total Estimated Cost: \$27,687.00