

RESOLUTION NO. 15-_____

WHEREAS, the Huntsville Electric Utility Board has approved Purchase Requisition PR-10184270, which allows for the purchase of replacement insulators for the Farley 46kV switching station, which are aged and showing deterioration, at an estimated cost of \$58,490.00; and

WHEREAS, the expenditure of such amount being in excess of the sum of \$25,000.00 requires the consent and approval of the City Council of the City of Huntsville, Alabama.

NOW, THEREFORE, BE IT RESOLVED by the City Council of the City of Huntsville, Alabama, that the purchase of replacement insulators for the Farley 46kV switching station, which are aged and showing deterioration, at an estimated cost of \$58,490.00, be, and the same is hereby approved, and the written consent and approval of the City Council of the City of Huntsville, Alabama, is hereby given to the Huntsville Electric Utility Board for the expenditure of sufficient funds from the proper fund belonging to the Huntsville Electric Utility Board.

ADOPTED this the _____ day of _____, 2015.

President of the City Council of
The City of Huntsville, Alabama

APPROVED this the _____ day of _____, 2015.

Mayor of the City of Huntsville,
Alabama



HUNTSVILLE UTILITIES

Electricity – Natural Gas – Water

(256) 535-1200

www.hsvutil.org

P.O. Box 2048
Huntsville, AL 35804

REQUEST FOR APPROVAL

Purchase Requisition #10184270

Purchase Requisition #10184270 – 46kV Insulators at Farley Primary

Request the purchase of insulators at Farley Primary Substation. These insulators will provide replacements for the Farley 46kV switching station, which are 50 years old and showing signs of deterioration. To prevent further unplanned outages these insulators need to be replaced. This is a non-budgeted Capital item, WBS #SUB-M.FARP.E_A0100.

Total Estimated Cost: \$58,490.00