



**RESOLUTION 16- \_\_\_\_\_**

**WHEREAS,** the City of Huntsville Waterworks Utility Board has approved Purchase Requisition #10227244 which provides for purchase of outside services and material to repair the #1 raw water pump at the South Parkway Water Treatment Plant which includes disassembling, sandblasting, replacing the line and head shaft for the water pump, and installing a new bowl assembly and welding to the existing 18 inch column at a total estimated cost of \$91,388.00; and

**WHEREAS,** the estimated cost of said purchase is in excess of \$25,000.00 and requires the consent and approval of the City Council of the City of Huntsville, Alabama;

**NOW, THEREFORE, BE IT RESOLVED,** by the City Council of the City of Huntsville, Alabama that Purchase Requisition #10227244 which provides for purchase of outside services and material to repair the #1 raw water pump at the South Parkway Water Treatment Plant which includes disassembling, sandblasting, replacing the line and head shaft for the water pump, and installing a new bowl assembly and welding to the existing 18 inch column at a total estimated cost of \$91,388.00 be, and the same is hereby approved and written consent and approval of the City Council of the City of Huntsville is hereby granted to the City of Huntsville Waterworks Utility Board for the expenditure of sufficient funds from the proper fund belonging to the City of Huntsville Waterworks Utility Board for the payment of the cost thereof.

**ADOPTED** this the \_\_\_\_\_ day of \_\_\_\_\_, 2016.

\_\_\_\_\_  
President of the City Council of  
the City of Huntsville, Alabama

**APPROVED** this the \_\_\_\_\_ day of \_\_\_\_\_, 2016.

\_\_\_\_\_  
Mayor of the City of Huntsville,  
Alabama



## **REQUEST FOR APPROVAL**

### **Purchase Requisition #10227244**

Purchase Requisition #10227244 – Emergency Repair for Raw Water Pump

Request the approval to purchase outside services and materials to repair the #1 raw water pump at the South Parkway Water Treatment Plant. This work includes disassembling, sandblasting, replacing the line and head shaft for the water pump, installing a new bowl assembly, and welding to the existing 18-inch column. This is a non-budgeted FY16 Expense item, WBS #O&M-WP.WPKWY.MNTEQ.

**Total Estimated Cost: \$91,388.00**