



HUNTSVILLE

Shane Davis, P.E.
Director of
City Engineering

Tommy Battle
Mayor

REDSTONE GATEWAY PACKAGE 1B-5 GRAVITY SANITARY SEWER

Project No. 65-11-SP05

March 28, 2011

Addendum #2

All addenda and attachments for the above- referenced project will become part of the contract documents.

Bid Opening **POSTPONED** until Wednesday, **March 30, 2011 at 3:00 p.m.** in the City of Huntsville Public Services Building, 1st Floor Conference Room, 320 Fountain Circle, Huntsville, AL

CONTRACTOR QUESTIONS:

1. **Q.** Will the delivery drivers be required to have Redstone Arsenal Security Clearance and/or have to be escorted to access the secured areas?
A. Yes, all deliveries to "secure areas" (within the Redstone Arsenal secured fence areas), will have to go through Gate 1 of the Arsenal. Time sensitive materials may be delivered through Gate 9 with written permission from the Arsenal and coordinated through Brasfield & Gorrie as discussed at the Pre-Bid Meeting. Please note deliveries to the unsecure areas of the project will not require Redstone Arsenal Security clearance.
2. **Q.** Will dirt be allowed to be temporarily stockpiled outside the limits of construction referenced in the Specifications on Page 3. "The limits of construction for the Gravity Sanitary Sewer System shall be the proposed road right of ways and/or thirty (30) foot wide temporary construction easement along each side of the twenty (20) foot sanitary easement?"
A. Yes, however the location must be approved prior to placement with the Owner's Project Manager.
3. **Q.** Supplement to General Requirements, Page 4, Item 5. The successful Contractor shall establish an office in Huntsville, Alabama, with telephone service, and shall maintain close liaison with the Owner. Will the Type II trailer meet this requirement?
A. A Trailer will meet this requirement, however, the "Type II Trailer" has been removed as a line item on the bid form and will need to be included as an incidental cost to the project if the Prime Contractor does not have an existing office in Huntsville, Alabama.

The Star of Alabama

4. **Q.** Can the blasting regulations for the City of Huntsville and Redstone Arsenal be provided?
A. Refer to the attached link to the City of Huntsville Environmental Management and Natural Resources Department for blasting regulations - <http://www.hsvcity.com/natres/blast%20.htm> referenced in Section 202.03-Construction Requirements paragraph E. and Section 203-Rock Removal of the City of Huntsville Engineering Department Design and Acceptance Manual for Sanitary Sewers, dated November 2005. Redstone Arsenal does not require a blasting permit, however Contractors will be required to coordinate with the Garrison Safety office, Emergency Services Directorate which operates the gate, and Redstone Security.

5. **Q.** Can dirt spoils be disposed of on-site?
A. Yes, excess material may be placed on-site South of Overlook Road or with-in the Redstone Arsenal property if coordinated with COH Project Manager.

6. **Q.** Is this a Davis-Bacon Project?
A. No.

7. **Q.** What is the DBE required percentages?
A. No minimum participation percentage is required, but all contractors shall engage in outreach efforts to encourage DBE/MBE/WBE participation on this project.

8. **Q.** How long does the badge/security process take to be processed and what requirements are needed for badges?
A. It takes approximately 10 business days for the badge/clearance process and will be coordinated through Brasfield & Gorrie. A driver's license, Social Security Number, and place of birth is required and a background search will be performed on each person requesting clearance.

9. **Q.** At manhole 2D there is a continuation of 330' of 6"DIP with 4 cleanouts and 87' of casing pipe, is that work to be performed under this package and if so what bid item is it to be covered under or is it incidental to the project? Also can you provide a detail for the cleanouts that are in the casing pipe?
A. This lateral, cleanouts, and casing have all been deleted from this project scope of work. See Question #20 in Addendum #1 which removes this work.

Last day for questions concerning this bid package was **Friday, March 25, 2011, at 5:00 p.m.** This shall be considered the Final Addendum for this bid package and it was issued on **Monday, March 28, 2011.**

All addenda must be acknowledged either on the outside of the bid envelope or in the bid proposal.

END OF ADDENDUM #2